

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 12)**

Water Level of the accumulated water (at 7:00 on August 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,892 mm (22 mm decrease since 7:00 on August 11)	O.P.+ 2,495 mm (4 mm increase since 7:00 on August 11)	—
	Water level of Turbine Building	O.P.+ 2,622 mm (14 mm increase since 7:00 on August 11)	O.P.+ 2,905 mm (19 mm decrease since 7:00 on August 11)	O.P.+ 2,680 mm (48 mm increase since 7:00 on August 11)	O.P.+ 2,641 mm (5 mm decrease since 7:00 on August 11)
	Water level of Reactor Building	O.P.+ 4,203 mm (22 mm increase since 7:00 on August 11)	O.P.+ 3,023 mm (36 mm decrease since 7:00 on August 11)	O.P.+ 2,670 mm (43 mm increase since 7:00 on August 11)	O.P.+ 2,736 mm (16 mm decrease since 7:00 on August 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,161 mm (Increase from initial level:5,378 mm, 4 mm increase since 7:00 on August 11) O.P.+ 2,135 mm (Increase from initial level:2,861 mm, 185 mm decrease since 7:00 on August 11) O.P.+ 4,325 mm (Water level from floor:529 mm, 8 mm increase since 7:00 on August 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on August 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (Since 9:58 on August 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Currently being transferred	(From 10:00 on August 11 to 15:00 on August 11)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 14:10 on August 7 to 8:23 on August 12   Stop Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:23 AM on August 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.