

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 13)**

Water Level of the accumulated water (at 7:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,866 mm (26 mm decrease since 7:00 on August 12)	O.P.+ 2,520 mm (25 mm increase since 7:00 on August 12)	—
	Water level of Turbine Building	O.P.+ 2,636 mm (14 mm increase since 7:00 on August 12)	O.P.+ 2,883 mm (22 mm decrease since 7:00 on August 12)	O.P.+ 2,706 mm (26 mm increase since 7:00 on August 12)	O.P.+ 2,655 mm (14 mm increase since 7:00 on August 12)
	Water level of Reactor Building	O.P.+ 4,221 mm (18 mm increase since 7:00 on August 12)	O.P.+ 3,004 mm (19 mm decrease since 7:00 on August 12)	O.P.+ 2,705 mm (35 mm increase since 7:00 on August 12)	O.P.+ 2,729 mm (7 mm decrease since 7:00 on August 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,165 mm (Increase from initial level:5,382 mm, 4 mm increase since 7:00 on August 12) O.P.+ 1,962 mm (Increase from initial level:2,688 mm, 173 mm decrease since 7:00 on August 12) O.P.+ 4,332 mm (Water level from floor:536 mm, 7 mm increase since 7:00 on August 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on August 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (Since 9:58 on August 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:35 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:23 AM on August 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:03 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 11:35 AM.				

※ For quick publication of the data of water level, values are provided as reference values.