

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 14)**

Water Level of the accumulated water (at 7:00 on August 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,846 mm (20 mm decrease since 7:00 on August 13)	O.P.+ 2,542 mm (22 mm increase since 7:00 on August 13)	—
	Water level of Turbine Building	O.P.+ 2,651 mm (15 mm increase since 7:00 on August 13)	O.P.+ 2,869 mm (14 mm decrease since 7:00 on August 13)	O.P.+ 2,727 mm (21 mm increase since 7:00 on August 13)	O.P.+ 2,673 mm (18 mm increase since 7:00 on August 13)
	Water level of Reactor Building	O.P.+ 4,224 mm (3 mm increase since 7:00 on August 13)	O.P.+ 2,985 mm (19 mm decrease since 7:00 on August 13)	O.P.+ 2,725 mm (20 mm increase since 7:00 on August 13)	O.P.+ 2,733 mm (4 mm increase since 7:00 on August 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,167 mm (Increase from initial level:5,384 mm, 2 mm increase since 7:00 on August 13) O.P.+ 1,685 mm (Increase from initial level:2,411 mm, 277 mm decrease since 7:00 on August 13) O.P.+ 4,339 mm (Water level from floor:543 mm, 7 mm increase since 7:00 on August 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on August 7)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:35 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.