

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 15)**

Water Level of the accumulated water (at 7:00 on August 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,823 mm (23 mm decrease since 7:00 on August 14)	O.P.+ 2,522 mm (20 mm decrease since 7:00 on August 14)	—
	Water level of Turbine Building	O.P.+ 2,666 mm (15 mm increase since 7:00 on August 14)	O.P.+ 2,851 mm (18 mm decrease since 7:00 on August 14)	O.P.+ 2,666 mm (61 mm decrease since 7:00 on August 14)	O.P.+ 2,672 mm (1 mm decrease since 7:00 on August 14)
	Water level of Reactor Building	O.P.+ 4,208 mm (16 mm decrease since 7:00 on August 14)	O.P.+ 2,970 mm (15 mm decrease since 7:00 on August 14)	O.P.+ 2,670 mm (55 mm decrease since 7:00 on August 14)	O.P.+ 2,738 mm (5 mm increase since 7:00 on August 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,168 mm (Increase from initial level:5,385 mm, 1 mm increase since 7:00 on August 14) O.P.+ 1,960 mm (Increase from initial level:2,686 mm, 275 mm increase since 7:00 on August 14) O.P.+ 4,346 mm (Water level from floor:550 mm, 7 mm increase since 7:00 on August 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on August 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:30 on August 14)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:35 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.