

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 19)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on August 19)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,631 mm (46 mm decrease since 7:00 on August 18)	O.P.+ 2,605 mm (45 mm increase since 7:00 on August 18)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (14 mm increase since 7:00 on August 18)	O.P.+ 2,690 mm (40 mm decrease since 7:00 on August 18)	O.P.+ 2,814 mm (69 mm increase since 7:00 on August 18)	O.P.+ 2,711 mm (18 mm increase since 7:00 on August 18)
	Water level of Reactor Building	O.P.+ 4,181 mm (4 mm decrease since 7:00 on August 18)	O.P.+ 2,832 mm (41 mm decrease since 7:00 on August 18)	O.P.+ 2,813 mm (68 mm increase since 7:00 on August 18)	O.P.+ 2,750 mm (9 mm increase since 7:00 on August 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,176 mm (Increase from initial level:5,393 mm, 2 mm increase since 7:00 on August 18) O.P.+ 1,437 mm (Increase from initial level:2,163 mm, 367 mm decrease since 7:00 on August 18) O.P.+ 4,376 mm (Water level from floor:580 mm, 8 mm increase since 7:00 on August 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:30 on August 14 to 19:03 on August 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on August 18 to 15:00 on August 18)	
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:35 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.