

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 20)**

Water Level of the accumulated water (at 7:00 on August 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,589 mm (42 mm decrease since 7:00 on August 19)	O.P.+ 2,657 mm (52 mm increase since 7:00 on August 19)	—
	Water level of Turbine Building	O.P.+ 2,740 mm (16 mm increase since 7:00 on August 19)	O.P.+ 2,651 mm (39 mm decrease since 7:00 on August 19)	O.P.+ 2,855 mm (41 mm increase since 7:00 on August 19)	O.P.+ 2,747 mm (36 mm increase since 7:00 on August 19)
	Water level of Reactor Building	O.P.+ 4,169 mm (12 mm decrease since 7:00 on August 19)	O.P.+ 2,795 mm (37 mm decrease since 7:00 on August 19)	O.P.+ 2,866 mm (53 mm increase since 7:00 on August 19)	O.P.+ 2,767 mm (17 mm increase since 7:00 on August 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,177 mm (Increase from initial level:5,394 mm, 1 mm increase since 7:00 on August 19) O.P.+ 1,161 mm (Increase from initial level:1,887 mm, 276 mm decrease since 7:00 on August 19) O.P.+ 4,383 mm (Water level from floor:587 mm, 7 mm increase since 7:00 on August 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:35 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.