

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 21)**

Water Level of the accumulated water (at 7:00 on August 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,549 mm (40 mm decrease since 7:00 on August 20)	O.P.+ 2,667 mm (10 mm increase since 7:00 on August 20)	—
	Water level of Turbine Building	O.P.+ 2,755 mm (15 mm increase since 7:00 on August 20)	O.P.+ 2,616 mm (35 mm decrease since 7:00 on August 20)	O.P.+ 2,861 mm (6 mm increase since 7:00 on August 20)	O.P.+ 2,777 mm (30 mm increase since 7:00 on August 20)
	Water level of Reactor Building	O.P.+ 4,152 mm (17 mm decrease since 7:00 on August 20)	O.P.+ 2,760 mm (35 mm decrease since 7:00 on August 20)	O.P.+ 2,871 mm (5 mm increase since 7:00 on August 20)	O.P.+ 2,788 mm (21 mm increase since 7:00 on August 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,179 mm (Increase from initial level:5,396 mm, 2 mm increase since 7:00 on August 20) O.P.+ 1,136 mm (Increase from initial level:1,862 mm, 25 mm decrease since 7:00 on August 20) O.P.+ 4,390 mm (Water level from floor:594 mm, 7 mm increase since 7:00 on August 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:02 on August 21 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:02 AM on August 21, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) for vessel replacement.				

※ For quick publication of the data of water level, values are provided as reference values.