

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 26)**

Water Level of the accumulated water (at 7:00 on August 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (50 mm increase since 7:00 on August 25)	O.P.+ 2,530 mm (30 mm decrease since 7:00 on August 25)	—
	Water level of Turbine Building	O.P.+ 2,818 mm (11 mm increase since 7:00 on August 25)	O.P.+ 2,911 mm (59 mm increase since 7:00 on August 25)	O.P.+ 2,641 mm (37 mm decrease since 7:00 on August 25)	O.P.+ 2,698 mm (27 mm decrease since 7:00 on August 25)
	Water level of Reactor Building	O.P.+ 4,162 mm (20 mm increase since 7:00 on August 25)	O.P.+ 3,003 mm (60 mm increase since 7:00 on August 25)	O.P.+ 2,640 mm (40 mm decrease since 7:00 on August 25)	O.P.+ 2,778 mm (15 mm decrease since 7:00 on August 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,197 mm (Increase from initial level:5,414 mm, 2 mm increase since 7:00 on August 25) O.P.+ 1,482 mm (Increase from initial level:2,208 mm, 9 mm increase since 7:00 on August 25) O.P.+ 4,425 mm (Water level from floor:629 mm, 7 mm increase since 7:00 on August 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:26 on August 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.