

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 27)**

Water Level of the accumulated water (at 7:00 on August 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,982 mm (62 mm increase since 7:00 on August 26)	O.P.+ 2,505 mm (25 mm decrease since 7:00 on August 26)	—
	Water level of Turbine Building	O.P.+ 2,835 mm (17 mm increase since 7:00 on August 26)	O.P.+ 2,978 mm (67 mm increase since 7:00 on August 26)	O.P.+ 2,631 mm (10 mm decrease since 7:00 on August 26)	O.P.+ 2,671 mm (27 mm decrease since 7:00 on August 26)
	Water level of Reactor Building	O.P.+ 4,295 mm (133 mm increase since 7:00 on August 26)	O.P.+ 3,092 mm (89 mm increase since 7:00 on August 26)	O.P.+ 2,634 mm (6 mm decrease since 7:00 on August 26)	O.P.+ 2,760 mm (18 mm decrease since 7:00 on August 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,202 mm (Increase from initial level:5,419 mm, 5 mm increase since 7:00 on August 26) O.P.+ 1,493 mm (Increase from initial level:2,219 mm, 11 mm increase since 7:00 on August 26) O.P.+ 4,434 mm (Water level from floor:638 mm, 9 mm increase since 7:00 on August 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:26 on August 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.