

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 28)**

Water Level of the accumulated water (at 7:00 on August 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,961 mm (21 mm decrease since 7:00 on August 27)	O.P.+ 2,501 mm (4 mm decrease since 7:00 on August 27)	—
	Water level of Turbine Building	O.P.+ 2,578 mm (257 mm decrease since 7:00 on August 27)	O.P.+ 2,953 mm (25 mm decrease since 7:00 on August 27)	O.P.+ 2,677 mm (46 mm increase since 7:00 on August 27)	O.P.+ 2,654 mm (17 mm decrease since 7:00 on August 27)
	Water level of Reactor Building	O.P.+ 4,374 mm (79 mm increase since 7:00 on August 27)	O.P.+ 3,086 mm (6 mm decrease since 7:00 on August 27)	O.P.+ 2,670 mm (36 mm increase since 7:00 on August 27)	O.P.+ 2,741 mm (19 mm decrease since 7:00 on August 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,205 mm (Increase from initial level:5,422 mm, 3 mm increase since 7:00 on August 27) O.P.+ 1,508 mm (Increase from initial level:2,234 mm, 15 mm increase since 7:00 on August 27) O.P.+ 4,441 mm (Water level from floor:645 mm, 7 mm increase since 7:00 on August 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer suspended (From 9:54 on August 27 to 18:15 on August 27)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:37 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:26 on August 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.