

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 29)**

Water Level of the accumulated water (at 7:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,926 mm (35 mm decrease since 7:00 on August 28)	O.P.+ 2,511 mm (10 mm increase since 7:00 on August 28)	—
	Water level of Turbine Building	O.P.+ 2,601 mm (23 mm increase since 7:00 on August 28)	O.P.+ 2,913 mm (40 mm decrease since 7:00 on August 28)	O.P.+ 2,704 mm (27 mm increase since 7:00 on August 28)	O.P.+ 2,662 mm (8 mm increase since 7:00 on August 28)
	Water level of Reactor Building	O.P.+ 4,427 mm (53 mm increase since 7:00 on August 28)	O.P.+ 3,052 mm (34 mm decrease since 7:00 on August 28)	O.P.+ 2,702 mm (32 mm increase since 7:00 on August 28)	O.P.+ 2,731 mm (10 mm decrease since 7:00 on August 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,208 mm (Increase from initial level:5,425 mm, 3 mm increase since 7:00 on August 28) O.P.+ 1,770 mm (Increase from initial level:2,496 mm, 262 mm increase since 7:00 on August 28) O.P.+ 4,442 mm (Water level from floor:646 mm, 1 mm increase since 7:00 on August 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:37 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:07 on August 28   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:01 AM on August 28, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 3:23 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 4:07 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.