

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 1)**

Water Level of the accumulated water (at 7:00 on September 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,885 mm (21 mm increase since 7:00 on August 31)	O.P.+ 2,535 mm (9 mm decrease since 7:00 on August 31)	—
	Water level of Turbine Building	O.P.+ 2,670 mm (22 mm increase since 7:00 on August 31)	O.P.+ 2,864 mm (28 mm increase since 7:00 on August 31)	O.P.+ 2,700 mm (35 mm decrease since 7:00 on August 31)	O.P.+ 2,691 mm (5 mm increase since 7:00 on August 31)
	Water level of Reactor Building	O.P.+ 4,498 mm (9 mm increase since 7:00 on August 31)	O.P.+ 2,970 mm (9 mm decrease since 7:00 on August 31)	O.P.+ 2,708 mm (28 mm decrease since 7:00 on August 31)	O.P.+ 2,745 mm (6 mm increase since 7:00 on August 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,216 mm (Increase from initial level:5,433 mm, 1 mm increase since 7:00 on August 31) O.P.+ 1,936 mm (Increase from initial level:2,662 mm, 58 mm increase since 7:00 on August 31) O.P.+ 4,469 mm (Water level from floor:673 mm, 7 mm increase since 7:00 on August 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:37 on August 27 to 18:08 on August 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:07 on August 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.