

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 3)**

Water Level of the accumulated water (at 7:00 on September 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,996 mm (50 mm increase since 7:00 on September 2)	O.P.+ 2,476 mm (32 mm decrease since 7:00 on September 2)	—
	Water level of Turbine Building	O.P.+ 2,711 mm (20 mm increase since 7:00 on September 2)	O.P.+ 2,996 mm (60 mm increase since 7:00 on September 2)	O.P.+ 2,602 mm (45 mm decrease since 7:00 on September 2)	O.P.+ 2,650 mm (24 mm decrease since 7:00 on September 2)
	Water level of Reactor Building	O.P.+ 4,541 mm (24 mm increase since 7:00 on September 2)	O.P.+ 3,095 mm (59 mm increase since 7:00 on September 2)	O.P.+ 2,601 mm (49 mm decrease since 7:00 on September 2)	O.P.+ 2,727 mm (12 mm decrease since 7:00 on September 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,832 mm (Increase from initial level:5,049 mm, 233 mm decrease since 7:00 on September 2) O.P.+ 2,074 mm (Increase from initial level:2,800 mm, 79 mm increase since 7:00 on September 2) O.P.+ 4,225 mm (Water level from floor:429 mm, 6 mm increase since 7:00 on September 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:18 on August 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on September 2 to 15:00 on September 2)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:23 on September 1 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:07 on August 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.