

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 8)**

Water Level of the accumulated water (at 7:00 on September 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,941 mm (4 mm decrease since 7:00 on September 7)	O.P.+ 2,425 mm (30 mm increase since 7:00 on September 7)	—
	Water level of Turbine Building	O.P.+ 2,801 mm (19 mm increase since 7:00 on September 7)	O.P.+ 2,927 mm (5 mm decrease since 7:00 on September 7)	O.P.+ 2,621 mm (43 mm increase since 7:00 on September 7)	O.P.+ 2,577 mm (9 mm increase since 7:00 on September 7)
	Water level of Reactor Building	O.P.+ 4,660 mm (55 mm increase since 7:00 on September 7)	O.P.+ 3,070 mm (2 mm increase since 7:00 on September 7)	O.P.+ 2,615 mm (49 mm increase since 7:00 on September 7)	O.P.+ 2,652 mm (9 mm decrease since 7:00 on September 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,559 mm (Increase from initial level:4,776 mm, 3 mm increase since 7:00 on September 7) O.P.+ 2,489 mm (Increase from initial level:3,215 mm, 300 mm decrease since 7:00 on September 7) O.P.+ 4,261 mm (Water level from floor:465 mm, 7 mm increase since 7:00 on September 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:50 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.