

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 9)**

Water Level of the accumulated water (at 7:00 on September 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,943 mm (2 mm increase since 7:00 on September 8)	O.P.+ 2,449 mm (24 mm increase since 7:00 on September 8)	—
	Water level of Turbine Building	O.P.+ 2,821 mm (20 mm increase since 7:00 on September 8)	O.P.+ 2,928 mm (1 mm increase since 7:00 on September 8)	O.P.+ 2,643 mm (22 mm increase since 7:00 on September 8)	O.P.+ 2,594 mm (17 mm increase since 7:00 on September 8)
	Water level of Reactor Building	O.P.+ 4,664 mm (4 mm increase since 7:00 on September 8)	O.P.+ 3,061 mm (9 mm decrease since 7:00 on September 8)	O.P.+ 2,642 mm (27 mm increase since 7:00 on September 8)	O.P.+ 2,653 mm (1 mm increase since 7:00 on September 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,561 mm (Increase from initial level:4,778 mm, 2 mm increase since 7:00 on September 8) O.P.+ 2,183 mm (Increase from initial level:2,909 mm, 306 mm decrease since 7:00 on September 8) O.P.+ 4,269 mm (Water level from floor:473 mm, 8 mm increase since 7:00 on September 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:50 on September 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.