

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 10)**

Water Level of the accumulated water (at 7:00 on September 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,940 mm (3 mm decrease since 7:00 on September 9)	O.P.+ 2,471 mm (22 mm increase since 7:00 on September 9)	—
	Water level of Turbine Building	O.P.+ 2,842 mm (21 mm increase since 7:00 on September 9)	O.P.+ 2,925 mm (3 mm decrease since 7:00 on September 9)	O.P.+ 2,663 mm (20 mm increase since 7:00 on September 9)	O.P.+ 2,611 mm (17 mm increase since 7:00 on September 9)
	Water level of Reactor Building	O.P.+ 4,662 mm (2 mm decrease since 7:00 on September 9)	O.P.+ 3,053 mm (8 mm decrease since 7:00 on September 9)	O.P.+ 2,664 mm (22 mm increase since 7:00 on September 9)	O.P.+ 2,662 mm (9 mm increase since 7:00 on September 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,564 mm (Increase from initial level:4,781 mm, 3 mm increase since 7:00 on September 9) O.P.+ 1,882 mm (Increase from initial level:2,608 mm, 301 mm decrease since 7:00 on September 9) O.P.+ 4,276 mm (Water level from floor:480 mm, 7 mm increase since 7:00 on September 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:10 on September 10 to 15:00 on September 10)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:50 on September 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.