

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 11)**

Water Level of the accumulated water (at 7:00 on September 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,941 mm (1 mm increase since 7:00 on September 10)	O.P.+ 2,489 mm (18 mm increase since 7:00 on September 10)	—
	Water level of Turbine Building	O.P.+ 2,562 mm (280 mm decrease since 7:00 on September 10)	O.P.+ 2,926 mm (1 mm increase since 7:00 on September 10)	O.P.+ 2,681 mm (18 mm increase since 7:00 on September 10)	O.P.+ 2,627 mm (16 mm increase since 7:00 on September 10)
	Water level of Reactor Building	O.P.+ 4,658 mm (4 mm decrease since 7:00 on September 10)	O.P.+ 3,055 mm (2 mm increase since 7:00 on September 10)	O.P.+ 2,684 mm (20 mm increase since 7:00 on September 10)	O.P.+ 2,674 mm (12 mm increase since 7:00 on September 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,567 mm (Increase from initial level:4,784 mm, 3 mm increase since 7:00 on September 10) O.P.+ 1,565 mm (Increase from initial level:2,291 mm, 317 mm decrease since 7:00 on September 10) O.P.+ 4,283 mm (Water level from floor:487 mm, 7 mm increase since 7:00 on September 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer suspended (From 9:33 on September 10 to 18:32 on September 10)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:10 on September 10 to 15:00 on September 10)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 11:50 on September 4 to 8:27 on September 11   Stop Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:27 AM on September 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.