

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 12)**

Water Level of the accumulated water (at 7:00 on September 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,941 mm (No change since 7:00 on September 11)	O.P.+ 2,506 mm (17 mm increase since 7:00 on September 11)	—
	Water level of Turbine Building	O.P.+ 2,581 mm (19 mm increase since 7:00 on September 11)	O.P.+ 2,926 mm (No change since 7:00 on September 11)	O.P.+ 2,698 mm (17 mm increase since 7:00 on September 11)	O.P.+ 2,643 mm (16 mm increase since 7:00 on September 11)
	Water level of Reactor Building	O.P.+ 4,660 mm (2 mm increase since 7:00 on September 11)	O.P.+ 3,056 mm (1 mm increase since 7:00 on September 11)	O.P.+ 2,704 mm (20 mm increase since 7:00 on September 11)	O.P.+ 2,686 mm (12 mm increase since 7:00 on September 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,570 mm (Increase from initial level:4,787 mm, 3 mm increase since 7:00 on September 11) O.P.+ 1,420 mm (Increase from initial level:2,146 mm, 145 mm decrease since 7:00 on September 11) O.P.+ 4,289 mm (Water level from floor:493 mm, 6 mm increase since 7:00 on September 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:03 on September 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*At 8:27 AM on September 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:18 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:03 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.