

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 16)**

Water Level of the accumulated water (at 7:00 on September 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,936 mm (1 mm increase since 7:00 on September 15)	O.P.+ 2,452 mm (24 mm decrease since 7:00 on September 15)	—
	Water level of Turbine Building	O.P.+ 2,650 mm (16 mm increase since 7:00 on September 15)	O.P.+ 2,917 mm (1 mm decrease since 7:00 on September 15)	O.P.+ 2,606 mm (30 mm decrease since 7:00 on September 15)	O.P.+ 2,632 mm (16 mm decrease since 7:00 on September 15)
	Water level of Reactor Building	O.P.+ 4,683 mm (4 mm increase since 7:00 on September 15)	O.P.+ 3,051 mm (2 mm increase since 7:00 on September 15)	O.P.+ 2,609 mm (33 mm decrease since 7:00 on September 15)	O.P.+ 2,689 mm (13 mm decrease since 7:00 on September 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,578 mm (Increase from initial level:4,795 mm, 2 mm increase since 7:00 on September 15) O.P.+ 1,820 mm (Increase from initial level:2,546 mm, 191 mm increase since 7:00 on September 15) O.P.+ 4,315 mm (Water level from floor:519 mm, 7 mm increase since 7:00 on September 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:09 on September 13)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:40 on September 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.