

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 17)**

Water Level of the accumulated water (at 7:00 on September 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,933 mm (3 mm decrease since 7:00 on September 16)	O.P.+ 2,430 mm (22 mm decrease since 7:00 on September 16)	—
	Water level of Turbine Building	O.P.+ 2,666 mm (16 mm increase since 7:00 on September 16)	O.P.+ 2,914 mm (3 mm decrease since 7:00 on September 16)	O.P.+ 2,582 mm (24 mm decrease since 7:00 on September 16)	O.P.+ 2,614 mm (18 mm decrease since 7:00 on September 16)
	Water level of Reactor Building	O.P.+ 4,674 mm (9 mm decrease since 7:00 on September 16)	O.P.+ 3,051 mm (No change since 7:00 on September 16)	O.P.+ 2,580 mm (29 mm decrease since 7:00 on September 16)	O.P.+ 2,673 mm (16 mm decrease since 7:00 on September 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,583 mm (Increase from initial level:4,800 mm, 5 mm increase since 7:00 on September 16) O.P.+ 2,009 mm (Increase from initial level:2,735 mm, 189 mm increase since 7:00 on September 16) O.P.+ 4,321 mm (Water level from floor:525 mm, 6 mm increase since 7:00 on September 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:09 on September 13)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:40 on September 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.