

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 18)**

Water Level of the accumulated water (at 7:00 on September 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,929 mm (4 mm decrease since 7:00 on September 17)	O.P.+ 2,414 mm (16 mm decrease since 7:00 on September 17)	—
	Water level of Turbine Building	O.P.+ 2,681 mm (15 mm increase since 7:00 on September 17)	O.P.+ 2,910 mm (4 mm decrease since 7:00 on September 17)	O.P.+ 2,570 mm (12 mm decrease since 7:00 on September 17)	O.P.+ 2,597 mm (17 mm decrease since 7:00 on September 17)
	Water level of Reactor Building	O.P.+ 4,653 mm (21 mm decrease since 7:00 on September 17)	O.P.+ 3,048 mm (3 mm decrease since 7:00 on September 17)	O.P.+ 2,570 mm (10 mm decrease since 7:00 on September 17)	O.P.+ 2,660 mm (13 mm decrease since 7:00 on September 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,587 mm (Increase from initial level:4,804 mm, 4 mm increase since 7:00 on September 17) O.P.+ 2,202 mm (Increase from initial level:2,928 mm, 193 mm increase since 7:00 on September 17) O.P.+ 4,327 mm (Water level from floor:531 mm, 6 mm increase since 7:00 on September 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:09 on September 13)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:40 on September 13   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.