

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 19)**

Water Level of the accumulated water (at 7:00 on September 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,922 mm (7 mm decrease since 7:00 on September 18)	O.P.+ 2,426 mm (12 mm increase since 7:00 on September 18)	—
	Water level of Turbine Building	O.P.+ 2,696 mm (15 mm increase since 7:00 on September 18)	O.P.+ 2,903 mm (7 mm decrease since 7:00 on September 18)	O.P.+ 2,628 mm (58 mm increase since 7:00 on September 18)	O.P.+ 2,591 mm (6 mm decrease since 7:00 on September 18)
	Water level of Reactor Building	O.P.+ 4,637 mm (16 mm decrease since 7:00 on September 18)	O.P.+ 3,041 mm (7 mm decrease since 7:00 on September 18)	O.P.+ 2,621 mm (51 mm increase since 7:00 on September 18)	O.P.+ 2,652 mm (8 mm decrease since 7:00 on September 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,593 mm (Increase from initial level:4,810 mm, 6 mm increase since 7:00 on September 18) O.P.+ 2,186 mm (Increase from initial level:2,912 mm, 16 mm decrease since 7:00 on September 18) O.P.+ 4,333 mm (Water level from floor:537 mm, 6 mm increase since 7:00 on September 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:09 on September 13 to 10:03 on September 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:40 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:26 AM on September 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) and cleaned a filter. At 12:18 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1 2:40 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.