

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 22)**

Water Level of the accumulated water (at 7:00 on September 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,905 mm (7 mm decrease since 7:00 on September 21)	O.P.+ 2,481 mm (14 mm increase since 7:00 on September 21)	—
	Water level of Turbine Building	O.P.+ 2,726 mm (8 mm increase since 7:00 on September 21)	O.P.+ 2,882 mm (8 mm decrease since 7:00 on September 21)	O.P.+ 2,685 mm (17 mm increase since 7:00 on September 21)	O.P.+ 2,632 mm (14 mm increase since 7:00 on September 21)
	Water level of Reactor Building	O.P.+ 4,615 mm (5 mm decrease since 7:00 on September 21)	O.P.+ 3,014 mm (10 mm decrease since 7:00 on September 21)	O.P.+ 2,685 mm (19 mm increase since 7:00 on September 21)	O.P.+ 2,676 mm (9 mm increase since 7:00 on September 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,597 mm (Increase from initial level:4,814 mm, 2 mm increase since 7:00 on September 21) O.P.+ 1,507 mm (Increase from initial level:2,233 mm, 215 mm decrease since 7:00 on September 21) O.P.+ 4,350 mm (Water level from floor:554 mm, 5 mm increase since 7:00 on September 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:40 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.