

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 26)**

Water Level of the accumulated water (at 7:00 on September 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,890 mm (4 mm decrease since 7:00 on September 25)	O.P.+ 2,475 mm (22 mm decrease since 7:00 on September 25)	—
	Water level of Turbine Building	O.P.+ 2,749 mm (4 mm increase since 7:00 on September 25)	O.P.+ 2,863 mm (6 mm decrease since 7:00 on September 25)	O.P.+ 2,641 mm (39 mm decrease since 7:00 on September 25)	O.P.+ 2,652 mm (14 mm decrease since 7:00 on September 25)
	Water level of Reactor Building	O.P.+ 4,512 mm (54 mm decrease since 7:00 on September 25)	O.P.+ 2,992 mm (1 mm decrease since 7:00 on September 25)	O.P.+ 2,645 mm (45 mm decrease since 7:00 on September 25)	O.P.+ 2,705 mm (4 mm decrease since 7:00 on September 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,611 mm (Increase from initial level:4,828 mm, 3 mm increase since 7:00 on September 25) O.P.+ 1,803 mm (Increase from initial level:2,529 mm, 353 mm increase since 7:00 on September 25) O.P.+ 4,377 mm (Water level from floor:581 mm, 7 mm increase since 7:00 on September 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:47 on September 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:33 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:31 on September 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 6:47 AM on September 25, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) and cleaned a filter. At 10:46 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1 1:31 AM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.