

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 29)**

Water Level of the accumulated water (at 7:00 on September 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,947 mm (7 mm decrease since 7:00 on September 28)	O.P.+ 2,410 mm (23 mm decrease since 7:00 on September 28)	—
	Water level of Turbine Building	O.P.+ 2,756 mm (2 mm increase since 7:00 on September 28)	O.P.+ 2,926 mm (10 mm decrease since 7:00 on September 28)	O.P.+ 2,569 mm (25 mm decrease since 7:00 on September 28)	O.P.+ 2,602 mm (19 mm decrease since 7:00 on September 28)
	Water level of Reactor Building	O.P.+ 4,502 mm (12 mm increase since 7:00 on September 28)	O.P.+ 3,056 mm (7 mm decrease since 7:00 on September 28)	O.P.+ 2,564 mm (28 mm decrease since 7:00 on September 28)	O.P.+ 2,663 mm (17 mm decrease since 7:00 on September 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,619 mm (Increase from initial level:4,836 mm, 3 mm increase since 7:00 on September 28) O.P.+ 1,854 mm (Increase from initial level:2,580 mm, 180 mm increase since 7:00 on September 28) O.P.+ 4,396 mm (Water level from floor:600 mm, 6 mm increase since 7:00 on September 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:41 on September 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:33 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:31 on September 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.