

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 30)**

Water Level of the accumulated water (at 7:00 on September 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,942 mm (5 mm decrease since 7:00 on September 29)	O.P.+ 2,388 mm (22 mm decrease since 7:00 on September 29)	—
	Water level of Turbine Building	O.P.+ 2,760 mm (4 mm increase since 7:00 on September 29)	O.P.+ 2,919 mm (7 mm decrease since 7:00 on September 29)	O.P.+ 2,541 mm (28 mm decrease since 7:00 on September 29)	O.P.+ 2,580 mm (22 mm decrease since 7:00 on September 29)
	Water level of Reactor Building	O.P.+ 4,513 mm (11 mm increase since 7:00 on September 29)	O.P.+ 3,047 mm (9 mm decrease since 7:00 on September 29)	O.P.+ 2,538 mm (26 mm decrease since 7:00 on September 29)	O.P.+ 2,653 mm (10 mm decrease since 7:00 on September 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,623 mm (Increase from initial level:4,840 mm, 4 mm increase since 7:00 on September 29) O.P.+ 2,036 mm (Increase from initial level:2,762 mm, 182 mm increase since 7:00 on September 29) O.P.+ 4,402 mm (Water level from floor:606 mm, 6 mm increase since 7:00 on September 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:41 on September 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:33 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:31 on September 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.