

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 1)**

Water Level of the accumulated water (at 7:00 on October 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,931 mm (11 mm decrease since 7:00 on September 30)	O.P.+ 2,392 mm (4 mm increase since 7:00 on September 30)	—
	Water level of Turbine Building	O.P.+ 2,761 mm (1 mm increase since 7:00 on September 30)	O.P.+ 2,906 mm (13 mm decrease since 7:00 on September 30)	O.P.+ 2,593 mm (52 mm increase since 7:00 on September 30)	O.P.+ 2,567 mm (13 mm decrease since 7:00 on September 30)
	Water level of Reactor Building	O.P.+ 4,517 mm (4 mm increase since 7:00 on September 30)	O.P.+ 3,030 mm (17 mm decrease since 7:00 on September 30)	O.P.+ 2,585 mm (47 mm increase since 7:00 on September 30)	O.P.+ 2,639 mm (14 mm decrease since 7:00 on September 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,630 mm (Increase from initial level:4,847 mm, 7 mm increase since 7:00 on September 30) O.P.+ 1,783 mm (Increase from initial level:2,509 mm, 253 mm decrease since 7:00 on September 30) O.P.+ 4,408 mm (Water level from floor:612 mm, 6 mm increase since 7:00 on September 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:41 on September 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (From 13:33 on September 24 to 9:58 on September 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 30 to 15:00 on September 30)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:18 on October 1 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:18 AM on October 1, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.