

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 2)**

Water Level of the accumulated water (at 7:00 on October 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,984 mm (42 mm increase since 7:00 on October 1)	O.P.+ 2,411 mm (23 mm increase since 7:00 on October 1)	—
	Water level of Turbine Building	O.P.+ 2,762 mm (2 mm increase since 7:00 on October 1)	O.P.+ 2,967 mm (48 mm increase since 7:00 on October 1)	O.P.+ 2,618 mm (77 mm increase since 7:00 on October 1)	O.P.+ 2,576 mm (4 mm decrease since 7:00 on October 1)
	Water level of Reactor Building	O.P.+ 4,518 mm (5 mm increase since 7:00 on October 1)	O.P.+ 3,066 mm (19 mm increase since 7:00 on October 1)	O.P.+ 2,615 mm (77 mm increase since 7:00 on October 1)	O.P.+ 2,634 mm (19 mm decrease since 7:00 on October 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,635 mm (Increase from initial level:4,852 mm, 12 mm increase since 7:00 on October 1) O.P.+ 1,280 mm (Increase from initial level:2,006 mm, 756 mm decrease since 7:00 on October 1) O.P.+ 4,416 mm (Water level from floor:620 mm, 8 mm increase since 7:00 on October 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (From 14:41 on September 27 to 10:13 on October 1)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on October 1 to 15:00 on October 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on October 1   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:18 AM on October 1, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:11 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:43 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.