

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 3)**

Water Level of the accumulated water (at 7:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,981 mm (3 mm decrease since 7:00 on October 2)	O.P.+ 2,395 mm (16 mm decrease since 7:00 on October 2)	—
	Water level of Turbine Building	O.P.+ 2,763 mm (1 mm increase since 7:00 on October 2)	O.P.+ 2,964 mm (3 mm decrease since 7:00 on October 2)	O.P.+ 2,576 mm (42 mm decrease since 7:00 on October 2)	O.P.+ 2,576 mm (No change since 7:00 on October 2)
	Water level of Reactor Building	O.P.+ 4,526 mm (8 mm increase since 7:00 on October 2)	O.P.+ 3,089 mm (23 mm increase since 7:00 on October 2)	O.P.+ 2,576 mm (39 mm decrease since 7:00 on October 2)	O.P.+ 2,637 mm (3 mm increase since 7:00 on October 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,640 mm (Increase from initial level:4,857 mm, 5 mm increase since 7:00 on October 2) O.P.+ 1,295 mm (Increase from initial level:2,021 mm, 15 mm increase since 7:00 on October 2) O.P.+ 4,424 mm (Water level from floor:628 mm, 8 mm increase since 7:00 on October 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:07 on October 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on October 2)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on October 2 to 15:00 on October 2)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on October 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.