

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 6)**

Water Level of the accumulated water (at 7:00 on October 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,955 mm (3 mm decrease since 7:00 on October 5)	O.P.+ 2,331 mm (18 mm decrease since 7:00 on October 5)	—
	Water level of Turbine Building	O.P.+ 2,768 mm (3 mm increase since 7:00 on October 5)	O.P.+ 2,926 mm (10 mm decrease since 7:00 on October 5)	O.P.+ 2,507 mm (3 mm decrease since 7:00 on October 5)	O.P.+ 2,530 mm (15 mm decrease since 7:00 on October 5)
	Water level of Reactor Building	O.P.+ 4,605 mm (84 mm increase since 7:00 on October 5)	O.P.+ 3,076 mm (21 mm increase since 7:00 on October 5)	O.P.+ 2,524 mm (20 mm increase since 7:00 on October 5)	O.P.+ 2,605 mm (12 mm decrease since 7:00 on October 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,734 mm (Increase from initial level:4,951 mm, 1 mm increase since 7:00 on October 5) O.P.+ 1,802 mm (Increase from initial level:2,528 mm, 171 mm increase since 7:00 on October 5) O.P.+ 4,223 mm (Water level from floor:427 mm, 8 mm increase since 7:00 on October 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:07 on October 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on October 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on October 1   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.