

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 7)**

Water Level of the accumulated water (at 7:00 on October 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,003 mm (48 mm increase since 7:00 on October 6)	O.P.+ 2,420 mm (89 mm increase since 7:00 on October 6)	—
	Water level of Turbine Building	O.P.+ 2,994 mm (226 mm increase since 7:00 on October 6)	O.P.+ 3,024 mm (98 mm increase since 7:00 on October 6)	O.P.+ 2,542 mm (35 mm increase since 7:00 on October 6)	O.P.+ 2,535 mm (5 mm increase since 7:00 on October 6)
	Water level of Reactor Building	O.P.+ 4,976 mm (371 mm increase since 7:00 on October 6)	O.P.+ 3,122 mm (46 mm increase since 7:00 on October 6)	O.P.+ 2,538 mm (14 mm increase since 7:00 on October 6)	O.P.+ 2,606 mm (1 mm increase since 7:00 on October 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,742 mm (Increase from initial level:4,959 mm, 8 mm increase since 7:00 on October 6) O.P.+ 1,982 mm (Increase from initial level:2,708 mm, 180 mm increase since 7:00 on October 6) O.P.+ 4,242 mm (Water level from floor:446 mm, 19 mm increase since 7:00 on October 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:07 on October 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on October 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:43 on October 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 As for the water level of Unit 2 Turbine Building, we have started to adjust +100mm since 7:00 AM on October 3, 2014. *2 As for the water level of the vertical shaft at Unit 3, it is measured by the spare water gauge since 7:00 AM on October 3, 2014, because neighboring spare water gauge is more accurate.				

※ For quick publication of the data of water level, values are provided as reference values.