

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 8)**

Water Level of the accumulated water (at 7:00 on October 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,014 mm (11 mm increase since 7:00 on October 7)	O.P.+ 2,437 mm (17 mm increase since 7:00 on October 7)	—
	Water level of Turbine Building	O.P.+ 3,032 mm (38 mm increase since 7:00 on October 7)	O.P.+ 3,033 mm (9 mm increase since 7:00 on October 7)	O.P.+ 2,579 mm (37 mm increase since 7:00 on October 7)	O.P.+ 2,543 mm (8 mm increase since 7:00 on October 7)
	Water level of Reactor Building	O.P.+ 4,965 mm (11 mm decrease since 7:00 on October 7)	O.P.+ 3,126 mm (4 mm increase since 7:00 on October 7)	O.P.+ 2,575 mm (37 mm increase since 7:00 on October 7)	O.P.+ 2,604 mm (2 mm decrease since 7:00 on October 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,745 mm (Increase from initial level:4,962 mm, 3 mm increase since 7:00 on October 7) O.P.+ 1,768 mm (Increase from initial level:2,494 mm, 214 mm decrease since 7:00 on October 7) O.P.+ 4,252 mm (Water level from floor:456 mm, 10 mm increase since 7:00 on October 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:07 on October 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:10 on October 2 to 10:00 on October 7)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 7 to 15:00 on October 7)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:31 on October 8   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 7:31 AM on October 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.