

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 10)**

Water Level of the accumulated water (at 7:00 on October 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,017 mm (No change since 7:00 on October 9)	O.P.+ 2,490 mm (29 mm increase since 7:00 on October 9)	—
	Water level of Turbine Building	O.P.+ 2,800 mm (264 mm decrease since 7:00 on October 9)	O.P.+ 3,035 mm (1 mm increase since 7:00 on October 9)	O.P.+ 2,646 mm (32 mm increase since 7:00 on October 9)	O.P.+ 2,584 mm (23 mm increase since 7:00 on October 9)
	Water level of Reactor Building	O.P.+ 4,909 mm (19 mm decrease since 7:00 on October 9)	O.P.+ 3,116 mm (5 mm decrease since 7:00 on October 9)	O.P.+ 2,648 mm (40 mm increase since 7:00 on October 9)	O.P.+ 2,631 mm (17 mm increase since 7:00 on October 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,752 mm (Increase from initial level:4,969 mm, 5 mm increase since 7:00 on October 9) O.P.+ 1,617 mm (Increase from initial level:2,343 mm, 216 mm decrease since 7:00 on October 9) O.P.+ 4,275 mm (Water level from floor:479 mm, 10 mm increase since 7:00 on October 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:07 on October 2)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 9 to 15:00 on October 9)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:10 on October 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.