

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 14)**

Water Level of the accumulated water (at 7:00 on October 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,935 mm (18 mm decrease since 7:00 on October 13)	O.P.+ 2,559 mm (38 mm increase since 7:00 on October 13)	—
	Water level of Turbine Building	O.P.+ 3,140 mm (246 mm increase since 7:00 on October 13)	O.P.+ 2,946 mm (18 mm decrease since 7:00 on October 13)	O.P.+ 2,740 mm (52 mm increase since 7:00 on October 13)	O.P.+ 2,661 mm (22 mm increase since 7:00 on October 13)
	Water level of Reactor Building	O.P.+ 5,001 mm (138 mm increase since 7:00 on October 13)	O.P.+ 3,048 mm (6 mm decrease since 7:00 on October 13)	O.P.+ 2,795 mm (103 mm increase since 7:00 on October 13)	O.P.+ 2,696 mm (19 mm increase since 7:00 on October 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,764 mm (Increase from initial level:4,981 mm, 6 mm increase since 7:00 on October 13) O.P.+ 1,409 mm (Increase from initial level:2,135 mm, 22 mm increase since 7:00 on October 13) O.P.+ 4,309 mm (Water level from floor:513 mm, 13 mm increase since 7:00 on October 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:10 on October 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.