

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 15)**

Water Level of the accumulated water (at 7:00 on October 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,929 mm (6 mm decrease since 7:00 on October 14)	O.P.+ 2,578 mm (19 mm increase since 7:00 on October 14)	—
	Water level of Turbine Building	O.P.+ 3,278 mm (138 mm increase since 7:00 on October 14)	O.P.+ 2,941 mm (5 mm decrease since 7:00 on October 14)	O.P.+ 2,770 mm (30 mm increase since 7:00 on October 14)	O.P.+ 2,690 mm (29 mm increase since 7:00 on October 14)
	Water level of Reactor Building	O.P.+ 5,095 mm (94 mm increase since 7:00 on October 14)	O.P.+ 3,037 mm (11 mm decrease since 7:00 on October 14)	O.P.+ 2,779 mm (16 mm decrease since 7:00 on October 14)	O.P.+ 2,713 mm (17 mm increase since 7:00 on October 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,767 mm (Increase from initial level:4,984 mm, 3 mm increase since 7:00 on October 14) O.P.+ 1,435 mm (Increase from initial level:2,161 mm, 26 mm increase since 7:00 on October 14) O.P.+ 4,321 mm (Water level from floor:525 mm, 12 mm increase since 7:00 on October 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:20 on October 15   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:20 AM on October 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.