

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 16)**

Water Level of the accumulated water (at 7:00 on October 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,916 mm (13 mm decrease since 7:00 on October 15)	O.P.+ 2,589 mm (11 mm increase since 7:00 on October 15)	—
	Water level of Turbine Building	O.P.+ 2,895 mm (383 mm decrease since 7:00 on October 15)	O.P.+ 2,925 mm (16 mm decrease since 7:00 on October 15)	O.P.+ 2,782 mm (12 mm increase since 7:00 on October 15)	O.P.+ 2,715 mm (25 mm increase since 7:00 on October 15)
	Water level of Reactor Building	O.P.+ 5,046 mm (49 mm decrease since 7:00 on October 15)	O.P.+ 3,020 mm (17 mm decrease since 7:00 on October 15)	O.P.+ 2,795 mm (16 mm increase since 7:00 on October 15)	O.P.+ 2,729 mm (16 mm increase since 7:00 on October 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,768 mm (Increase from initial level:4,985 mm, 1 mm increase since 7:00 on October 15) O.P.+ 1,556 mm (Increase from initial level:2,282 mm, 121 mm increase since 7:00 on October 15) O.P.+ 4,329 mm (Water level from floor:533 mm, 8 mm increase since 7:00 on October 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 17:55 on October 15)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 15 to 15:00 on October 15)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:46 on September 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:41 on October 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:20 AM on October 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:20 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:41 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.