

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 17)**

Water Level of the accumulated water (at 7:00 on October 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,912 mm (4 mm decrease since 7:00 on October 16)	O.P.+ 2,601 mm (12 mm increase since 7:00 on October 16)	—
	Water level of Turbine Building	O.P.+ 2,709 mm (186 mm decrease since 7:00 on October 16)	O.P.+ 2,921 mm (4 mm decrease since 7:00 on October 16)	O.P.+ 2,799 mm (17 mm increase since 7:00 on October 16)	O.P.+ 2,736 mm (21 mm increase since 7:00 on October 16)
	Water level of Reactor Building	O.P.+ 5,009 mm (37 mm decrease since 7:00 on October 16)	O.P.+ 3,014 mm (6 mm decrease since 7:00 on October 16)	O.P.+ 2,816 mm (21 mm increase since 7:00 on October 16)	O.P.+ 2,744 mm (15 mm increase since 7:00 on October 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,771 mm (Increase from initial level:4,988 mm, 3 mm increase since 7:00 on October 16) O.P.+ 1,483 mm (Increase from initial level:2,209 mm, 73 mm decrease since 7:00 on October 16) O.P.+ 4,337 mm (Water level from floor:541 mm, 8 mm increase since 7:00 on October 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 17:55 on October 15 to 13:28 on October 16)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 16 to 15:00 on October 16)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:41 on October 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.