

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 20)**

Water Level of the accumulated water (at 7:00 on October 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,868 mm (18 mm decrease since 7:00 on October 19)	O.P.+ 2,636 mm (12 mm increase since 7:00 on October 19)	—
	Water level of Turbine Building	O.P.+ 2,821 mm (34 mm increase since 7:00 on October 19)	O.P.+ 2,873 mm (21 mm decrease since 7:00 on October 19)	O.P.+ 2,845 mm (15 mm increase since 7:00 on October 19)	O.P.+ 2,785 mm (15 mm increase since 7:00 on October 19)
	Water level of Reactor Building	O.P.+ 4,821 mm (72 mm decrease since 7:00 on October 19)	O.P.+ 2,955 mm (19 mm decrease since 7:00 on October 19)	O.P.+ 2,862 mm (17 mm increase since 7:00 on October 19)	O.P.+ 2,792 mm (14 mm increase since 7:00 on October 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,774 mm (Increase from initial level:4,991 mm, 1 mm increase since 7:00 on October 19) O.P.+ 1,322 mm (Increase from initial level:2,048 mm, 49 mm decrease since 7:00 on October 19) O.P.+ 4,358 mm (Water level from floor:562 mm, 7 mm increase since 7:00 on October 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:41 on October 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.