

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 21)**

| | | | | | |
|---|--|---|---|--|---|
| Water Level of the accumulated water (at 7:00 on October 21) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,865 mm (3 mm decrease since 7:00 on October 20) | O.P.+ 2,646 mm (10 mm increase since 7:00 on October 20) | — |
| | Water level of Turbine Building | O.P.+ 2,852 mm (31 mm increase since 7:00 on October 20) | O.P.+ 2,851 mm (22 mm decrease since 7:00 on October 20) | O.P.+ 2,858 mm (13 mm increase since 7:00 on October 20) | O.P.+ 2,799 mm (14 mm increase since 7:00 on October 20) |
| | Water level of Reactor Building | O.P.+ 4,765 mm (56 mm decrease since 7:00 on October 20) | O.P.+ 2,941 mm (14 mm decrease since 7:00 on October 20) | O.P.+ 2,879 mm (17 mm increase since 7:00 on October 20) | O.P.+ 2,805 mm (13 mm increase since 7:00 on October 20) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,778 mm (Increase from initial level:4,995 mm, 4 mm increase since 7:00 on October 20) O.P.+ 1,282 mm (Increase from initial level:2,008 mm, 40 mm decrease since 7:00 on October 20) O.P.+ 4,366 mm (Water level from floor:570 mm, 8 mm increase since 7:00 on October 20) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11) | — |
| | | Unit 5 and 6 | | | |
| | | Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 20 to 15:00 on October 20) | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:41 on October 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.