

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 23)**

Water Level of the accumulated water (at 7:00 on October 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,840 mm (18 mm decrease since 7:00 on October 22)	O.P.+ 2,671 mm (12 mm increase since 7:00 on October 22)	—
	Water level of Turbine Building	O.P.+ 2,911 mm (29 mm increase since 7:00 on October 22)	O.P.+ 2,817 mm (19 mm decrease since 7:00 on October 22)	O.P.+ 2,889 mm (17 mm increase since 7:00 on October 22)	O.P.+ 2,826 mm (14 mm increase since 7:00 on October 22)
	Water level of Reactor Building	O.P.+ 4,702 mm (20 mm decrease since 7:00 on October 22)	O.P.+ 2,909 mm (18 mm decrease since 7:00 on October 22)	O.P.+ 2,911 mm (16 mm increase since 7:00 on October 22)	O.P.+ 2,841 mm (21 mm increase since 7:00 on October 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,795 mm (Increase from initial level:5,012 mm, 12 mm increase since 7:00 on October 22) O.P.+ 1,220 mm (Increase from initial level:1,946 mm, 29 mm decrease since 7:00 on October 22) O.P.+ 4,379 mm (Water level from floor:583 mm, 7 mm increase since 7:00 on October 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:41 on October 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.