

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 24)**

Water Level of the accumulated water (at 7:00 on October 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,828 mm (12 mm decrease since 7:00 on October 23)	O.P.+ 2,683 mm (12 mm increase since 7:00 on October 23)	—
	Water level of Turbine Building	O.P.+ 2,939 mm (28 mm increase since 7:00 on October 23)	O.P.+ 2,787 mm (30 mm decrease since 7:00 on October 23)	O.P.+ 2,899 mm (10 mm increase since 7:00 on October 23)	O.P.+ 2,841 mm (15 mm increase since 7:00 on October 23)
	Water level of Reactor Building	O.P.+ 4,679 mm (23 mm decrease since 7:00 on October 23)	O.P.+ 2,882 mm (27 mm decrease since 7:00 on October 23)	O.P.+ 2,923 mm (12 mm increase since 7:00 on October 23)	O.P.+ 2,849 mm (8 mm increase since 7:00 on October 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,822 mm (Increase from initial level:5,039 mm, 27 mm increase since 7:00 on October 23) O.P.+ 1,324 mm (Increase from initial level:2,050 mm, 104 mm increase since 7:00 on October 23) O.P.+ 4,385 mm (Water level from floor:589 mm, 6 mm increase since 7:00 on October 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:46 on October 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on October 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:23 AM on October 23, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:51 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:43 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.