

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 27)**

Water Level of the accumulated water (at 7:00 on October 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,922 mm (65 mm increase since 7:00 on October 26)	O.P.+ 2,633 mm (33 mm decrease since 7:00 on October 26)	—
	Water level of Turbine Building	O.P.+ 2,811 mm (182 mm decrease since 7:00 on October 26)	O.P.+ 2,912 mm (77 mm increase since 7:00 on October 26)	O.P.+ 2,796 mm (51 mm decrease since 7:00 on October 26)	O.P.+ 2,826 mm (21 mm decrease since 7:00 on October 26)
	Water level of Reactor Building	O.P.+ 4,579 mm (35 mm decrease since 7:00 on October 26)	O.P.+ 2,960 mm (80 mm increase since 7:00 on October 26)	O.P.+ 2,820 mm (55 mm decrease since 7:00 on October 26)	O.P.+ 2,870 mm (3 mm decrease since 7:00 on October 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,935 mm (Increase from initial level:5,152 mm, 43 mm increase since 7:00 on October 26) O.P.+ 1,077 mm (Increase from initial level:1,803 mm, 76 mm decrease since 7:00 on October 26) O.P.+ 4,245 mm (Water level from floor:449 mm, 152 mm decrease since 7:00 on October 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:00 on October 26 to 15:57 on October 26)	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on October 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 10:20 AM to 3:33 PM on October 26, we started the transfer of accumulated water from the On-site Bunker Building to the Process Main Building.				

※ For quick publication of the data of water level, values are provided as reference values.