

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 28)**

Water Level of the accumulated water (at 7:00 on October 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,932 mm (10 mm increase since 7:00 on October 27)	O.P.+ 2,609 mm (24 mm decrease since 7:00 on October 27)	—
	Water level of Turbine Building	O.P.+ 2,835 mm (24 mm increase since 7:00 on October 27)	O.P.+ 2,921 mm (9 mm increase since 7:00 on October 27)	O.P.+ 2,774 mm (22 mm decrease since 7:00 on October 27)	O.P.+ 2,803 mm (23 mm decrease since 7:00 on October 27)
	Water level of Reactor Building	O.P.+ 4,560 mm (19 mm decrease since 7:00 on October 27)	O.P.+ 2,998 mm (38 mm increase since 7:00 on October 27)	O.P.+ 2,790 mm (30 mm decrease since 7:00 on October 27)	O.P.+ 2,853 mm (17 mm decrease since 7:00 on October 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,937 mm (Increase from initial level:5,154 mm, 2 mm increase since 7:00 on October 27) O.P.+ 1,191 mm (Increase from initial level:1,917 mm, 114 mm increase since 7:00 on October 27) O.P.+ 4,251 mm (Water level from floor:455 mm, 6 mm increase since 7:00 on October 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on October 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 27 to 15:00 on October 27)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on October 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	In accumulated water transportation from Unit 3 Turbine Building Basement to Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building), driving of two pumps was changed to one at 9:40 AM on October 27, 2014. The transportation is continuing.				

※ For quick publication of the data of water level, values are provided as reference values.