

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 30)**

Water Level of the accumulated water (at 7:00 on October 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,932 mm (5 mm increase since 7:00 on October 29)	O.P.+ 2,621 mm (16 mm increase since 7:00 on October 29)	—
	Water level of Turbine Building	O.P.+ 2,875 mm (20 mm increase since 7:00 on October 29)	O.P.+ 2,915 mm (4 mm decrease since 7:00 on October 29)	O.P.+ 2,840 mm (33 mm increase since 7:00 on October 29)	O.P.+ 2,789 mm (5 mm increase since 7:00 on October 29)
	Water level of Reactor Building	O.P.+ 4,501 mm (27 mm decrease since 7:00 on October 29)	O.P.+ 2,989 mm (2 mm decrease since 7:00 on October 29)	O.P.+ 2,855 mm (35 mm increase since 7:00 on October 29)	O.P.+ 2,831 mm (13 mm decrease since 7:00 on October 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,945 mm (Increase from initial level:5,162 mm, 4 mm increase since 7:00 on October 29) O.P.+ 1,442 mm (Increase from initial level:2,168 mm, 388 mm increase since 7:00 on October 29) O.P.+ 4,261 mm (Water level from floor:465 mm, 5 mm increase since 7:00 on October 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 29 to 15:00 on October 29)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on October 29 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.