

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 5)**

Water Level of the accumulated water (at 7:00 on November 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,936 mm (1 mm decrease since 7:00 on November 4)	O.P.+ 2,654 mm (18 mm increase since 7:00 on November 4)	—
	Water level of Turbine Building	O.P.+ 2,984 mm (20 mm increase since 7:00 on November 4)	O.P.+ 2,914 mm (1 mm decrease since 7:00 on November 4)	O.P.+ 2,880 mm (17 mm increase since 7:00 on November 4)	O.P.+ 2,825 mm (12 mm increase since 7:00 on November 4)
	Water level of Reactor Building	O.P.+ 4,531 mm (4 mm increase since 7:00 on November 4)	O.P.+ 2,983 mm (13 mm decrease since 7:00 on November 4)	O.P.+ 2,897 mm (18 mm increase since 7:00 on November 4)	O.P.+ 2,864 mm (10 mm increase since 7:00 on November 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,000 mm (Increase from initial level:5,217 mm, 17 mm increase since 7:00 on November 4) O.P.+ 1,046 mm (Increase from initial level:1,772 mm, 308 mm decrease since 7:00 on November 4) O.P.+ 4,300 mm (Water level from floor:504 mm, 6 mm increase since 7:00 on November 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:52 on October 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.