

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 6)**

| | | | | | |
|---|--|---|---|--|---|
| Water Level of the accumulated water (at 7:00 on November 6) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,931 mm (5 mm decrease since 7:00 on November 5) | O.P.+ 2,647 mm (7 mm decrease since 7:00 on November 5) | — |
| | Water level of Turbine Building | O.P.+ 3,003 mm (19 mm increase since 7:00 on November 5) | O.P.+ 2,911 mm (3 mm decrease since 7:00 on November 5) | O.P.+ 2,853 mm (27 mm decrease since 7:00 on November 5) | O.P.+ 2,831 mm (6 mm increase since 7:00 on November 5) |
| | Water level of Reactor Building | O.P.+ 4,526 mm (5 mm decrease since 7:00 on November 5) | O.P.+ 2,988 mm (5 mm increase since 7:00 on November 5) | O.P.+ 2,879 mm (18 mm decrease since 7:00 on November 5) | O.P.+ 2,874 mm (10 mm increase since 7:00 on November 5) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,003 mm (Increase from initial level:5,220 mm, 3 mm increase since 7:00 on November 5) O.P.+ 1,018 mm (Increase from initial level:1,744 mm, 28 mm decrease since 7:00 on November 5) O.P.+ 4,305 mm (Water level from floor:509 mm, 5 mm increase since 7:00 on November 5) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on November 6 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | At 8:28 AM on November 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. | | | | |

※ For quick publication of the data of water level, values are provided as reference values.