

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 7)**

Water Level of the accumulated water (at 7:00 on November 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,873 mm (58 mm decrease since 7:00 on November 6)	O.P.+ 2,627 mm (20 mm decrease since 7:00 on November 6)	—
	Water level of Turbine Building	O.P.+ 2,796 mm (207 mm decrease since 7:00 on November 6)	O.P.+ 2,910 mm (1 mm decrease since 7:00 on November 6)	O.P.+ 2,820 mm (33 mm decrease since 7:00 on November 6)	O.P.+ 2,818 mm (13 mm decrease since 7:00 on November 6)
	Water level of Reactor Building	O.P.+ 4,522 mm (4 mm decrease since 7:00 on November 6)	O.P.+ 2,993 mm (5 mm increase since 7:00 on November 6)	O.P.+ 2,840 mm (39 mm decrease since 7:00 on November 6)	O.P.+ 2,865 mm (9 mm decrease since 7:00 on November 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,011 mm (Increase from initial level:5,228 mm, 8 mm increase since 7:00 on November 6) O.P.+ 1,344 mm (Increase from initial level:2,070 mm, 326 mm increase since 7:00 on November 6) O.P.+ 4,312 mm (Water level from floor:516 mm, 7 mm increase since 7:00 on November 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:50 on November 6 to 16:08 on November 6)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on November 6 to 15:00 on November 6)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:34 on November 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:28 AM on November 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:48 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:34 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.