

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 10)**

Water Level of the accumulated water (at 7:00 on November 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,915 mm (14 mm decrease since 7:00 on November 9)	O.P.+ 2,573 mm (17 mm decrease since 7:00 on November 9)	—
	Water level of Turbine Building	O.P.+ 2,856 mm (20 mm increase since 7:00 on November 9)	O.P.+ 2,894 mm (16 mm decrease since 7:00 on November 9)	O.P.+ 2,733 mm (26 mm decrease since 7:00 on November 9)	O.P.+ 2,768 mm (18 mm decrease since 7:00 on November 9)
	Water level of Reactor Building	O.P.+ 4,513 mm (7 mm increase since 7:00 on November 9)	O.P.+ 2,988 mm (No change since 7:00 on November 9)	O.P.+ 2,747 mm (24 mm decrease since 7:00 on November 9)	O.P.+ 2,819 mm (16 mm decrease since 7:00 on November 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,029 mm (Increase from initial level:5,246 mm, 2 mm increase since 7:00 on November 9) O.P.+ 1,860 mm (Increase from initial level:2,586 mm, 216 mm increase since 7:00 on November 9) O.P.+ 4,330 mm (Water level from floor:534 mm, 7 mm increase since 7:00 on November 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:34 on November 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.