

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 11)**

Water Level of the accumulated water (at 7:00 on November 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,900 mm (15 mm decrease since 7:00 on November 10)	O.P.+ 2,553 mm (20 mm decrease since 7:00 on November 10)	—
	Water level of Turbine Building	O.P.+ 2,875 mm (19 mm increase since 7:00 on November 10)	O.P.+ 2,879 mm (15 mm decrease since 7:00 on November 10)	O.P.+ 2,711 mm (22 mm decrease since 7:00 on November 10)	O.P.+ 2,749 mm (19 mm decrease since 7:00 on November 10)
	Water level of Reactor Building	O.P.+ 4,511 mm (2 mm decrease since 7:00 on November 10)	O.P.+ 2,964 mm (24 mm decrease since 7:00 on November 10)	O.P.+ 2,720 mm (27 mm decrease since 7:00 on November 10)	O.P.+ 2,803 mm (16 mm decrease since 7:00 on November 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,037 mm (Increase from initial level:5,254 mm, 8 mm increase since 7:00 on November 10) O.P.+ 2,095 mm (Increase from initial level:2,821 mm, 235 mm increase since 7:00 on November 10) O.P.+ 4,336 mm (Water level from floor:540 mm, 6 mm increase since 7:00 on November 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:34 on November 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.