

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 12)**

Water Level of the accumulated water (at 7:00 on November 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,953 mm (53 mm increase since 7:00 on November 11)	O.P.+ 2,535 mm (18 mm decrease since 7:00 on November 11)	—
	Water level of Turbine Building	O.P.+ 2,894 mm (19 mm increase since 7:00 on November 11)	O.P.+ 2,939 mm (60 mm increase since 7:00 on November 11)	O.P.+ 2,685 mm (26 mm decrease since 7:00 on November 11)	O.P.+ 2,731 mm (18 mm decrease since 7:00 on November 11)
	Water level of Reactor Building	O.P.+ 4,520 mm (9 mm increase since 7:00 on November 11)	O.P.+ 2,999 mm (35 mm increase since 7:00 on November 11)	O.P.+ 2,695 mm (25 mm decrease since 7:00 on November 11)	O.P.+ 2,786 mm (17 mm decrease since 7:00 on November 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,044 mm (Increase from initial level:5,261 mm, 7 mm increase since 7:00 on November 11) O.P.+ 1,951 mm (Increase from initial level:2,677 mm, 144 mm decrease since 7:00 on November 11) O.P.+ 4,344 mm (Water level from floor:548 mm, 8 mm increase since 7:00 on November 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:43 on October 27 to 9:54 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:14 on November 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on November 11 to 15:00 on November 11)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:34 on November 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.